

CHATHAM COUNTY HEALTH DEPARTMENT ENVIRONMENTAL HEALTH DIVISION

80 East Street ▪ P. O. Box 130 ▪ Pittsboro, NC 27312-0130
Phone (919) 542-8208 ▪ Fax (919) 542-8288

OFFICE USE ONLY

TPN _____
Permit No. _____
Date _____
EHS _____
System Type _____

Improvement Permit for Wastewater Systems ARTICLE II-CHAPTER 130A OF THE NC GENERAL STATUTES

NEW REPAIR EXPANSION REVISED

An Improvement Permit is issued to Parola Spisak for
a 6+ acre site located Halcy Meadows lot 2

in Chatham County. It is specifically issued for the following facility:

Facility: Residential () Non-Residential ()
No. Bedrooms 4 No. Residents/Employees 8 max
Type Wastewater: Residential () Commercial ()
Initial System Type: I () II () III () IV () V () VI ()

Description _____

Type System: Shallow Conventional () LPP ()
Other _____

Design Flow 480 GPD Application Rate 3 GPD/ft²

Size Tank(s) w/Risers and Effluent Filter ST 1000 Gal PT _____ Gal

Nitrification Line (Length/Width/Max Depth) 540' x 3' x 18" conv. or 400' x 3' x 18" Accepted

(On contour in approved septic area; sch. 40 PVC required over step-downs)

Repair System Type: I () II () III () IV () V () VI ()
Description Accepted

Special Conditions _____

A plat with site plan showing specific location of the facility, the site for the proposed wastewater system, existing buildings, property lines, water supplies, surface waters, the conditions for any site modifications; and any other information required by the department must be attached to be valid.

Septic tank riser 6" above grade required over outlet access port as a visible marker for the septic tank. Solid PVC with elbows must be used to construct conveyance over dams or stepdowns.

This permit is valid [] without expiration [] for five years but is subject to revocation if the site is altered, soil disturbed, set-backs violated, or the plans of intended use are changed.

The Improvement Permit shall not be affected by change in ownership.

THIS IS NOT AUTHORIZATION TO INSTALL. An authorization for Wastewater Construction must be obtained from this department before installation.

Issued by Thomas J. Boyer R.S.
Environmental Health Specialist

N.C. Registration Number 1353

Date 11-23-11

911 Address

Name Halcy Meadows lot 2

